



KEY - Resurfacing	
	Plane 40mm (Approx. 2080m2) and replace with: 40mm HRA55/10 C surf 60PSV Clause 911
	Access area to be resurfaced (55m2), excavate 100mm and overlay with: 40mm HRA55/10 C surf 60PSV Clause 911 60mm AC20 HDM bin 40/60
KEY - Ironwork and Drainage	
All gullies and manholes to be cleaned, and connections and main run to be jetted.	
■ G	Existing gully
■ Grp	Gully - grating and frame to be removed to recycling centre off site and replaced with new D400 cover and frame.
■ Grs	Gully - grating and frame to be reset
■ MH	Existing Manhole
■ MHrp	Existing manhole - cover and frame to be replaced with new 600x600mm D400 cover and frame
■ MHrs	Existing manhole - cover and frame to be reset
■ SV	Existing Sluice Valve
■ SVrp	Existing Sluice Valve cover and frame to be replace
■ FHrs	Existing Fire Hydrant cover and frame to be reset

- NOTES - GENERAL**
- Do not scale from this drawing. If in doubt contact telford and wrekin council - highways, transportation and engineering (twc - hte).
 - All dimensions are in metres (m) unless otherwise noted.
 - This drawing is to be read in conjunction with all other relevant drawings relating to this project.
 - All dimensions should be checked on site prior to construction. Any discrepancies are to be immediately reported in writing to twc - hte.
 - The contractor shall, prior to construction, check and verify that the details shown on this drawing are fully compatible with any as constructed dimensions or levels. Any discrepancies are to be immediately reported in writing to twc - hte.
 - This drawing has been prepared for the exclusive use of the commissioning party and unless agreed in writing by twc - hte no other party may use or rely on its contents. No liability is accepted by twc - hte for any use of this drawing other than for the purpose for which it was originally prepared.
 - It should be noted that this drawing may include data provided by third parties. No liability is accepted by twc - hte as to the accuracy of this data.
 - This drawing shall not be reproduced in any way without the written permission of twc - hte.
 - All personnel must comply with their own company risk assessments and method statements, and comply with the requirements of balfour beatty health and safety policy.

- NOTES - CARRIAGEWAY**
- This drawing should only be read in relation to the subject of the title. Other information shown on the drawing is to be considered indicative only. Reference should be made to appropriate drawing series for other information.
 - All patching/resurfacing, kerbing and ironwork must be marked out in the presence of the Project Manager and agreed prior to the commencement of any works on site.
 - Bond Coat to MCHW Clause 920 is required at all bound layer interfaces within the pavement, this includes planed surfaces and new asphalt layers.
 - All joints, kerbs and ironwork must be cleaned of dust and debris and all vertical faces to be painted with bitumen prior to resurfacing.
 - Planed surface must be swept clean and inspected immediately following planing in order to determine the extents of any areas of deep patching. Any loose or delaminating material should be brought to the attention of the Project Manager and must also be removed.
 - All bituminous materials to be transported, laid and compacted in accordance with BS 5948:2015
 - All ironwork to BS EN 124:2015

Rev	Revision/Issue Date	Purpose of Revision/Issue	Drawn	Checked	Approved
T2	25.05.22	Core summary and SHE box amended with PAH information	SW	NL	NL
T1	06.04.22	Issued for pricing	SW	NL	NL

Telford & Wrekin Council
 a co-operative council

Dean Sargeant, Director, Neighbourhood & Enforcement Services, Addenbrooke House, Telford, TF3 4NT

Client: **Telford & Wrekin Council**

Project: **HM22/23 - Sinclair Gardens**

Drawing title: **Resurfacing, Kerbing and Ironwork**

Drawing status: **D2 - FOR PRICING**

Scale: 1:500 | A1 | Date: 22/02/2022 | Drawn-by: SW | Checked-by: NL | Approved-by: NL

DO NOT SCALE FROM THIS DRAWING

Drawing number: **SINGAR-TWC-HPV-01-DR-CH-0700** | Rev: T2

SAFETY, HEALTH AND ENVIRONMENTAL (SHE) INFORMATION	
In addition to the hazards/risks normally associated with the types of work detailed on this drawing, note the following:	
CONSTRUCTION	
<ul style="list-style-type: none"> Numerous utilities including: LP Gas main, BT (underground and overhead), Virgin media, STW Water main, Surface water and Foul water sewers, LV & HV electric (underground). Refer to STATS plans for further information. Coring and PAH testing has confirmed no hazardous material is present 	
MAINTENANCE / CLEANING	
- As above	
ALTERATION / DEMOLITION	
- As above	
It is assumed that all works will be carried out by a competent contractor working, where appropriate, to an approved method statement	

Based on Ordnance Survey 1250 mapping with the permission of the Controller of Her Majesty's Stationary Office. Crown Copyright. Unauthorised reproduction infringes Crown Copyright and may lead to Prosecution or Civil proceedings. Telford & Wrekin Council Licence No. 100019694 Date 2020