



Operator	EG on the Move Ltd
Installation Address	Telford Service Station Shawbirch Crossroads Shawbirch Road Telford TF1 3QA
Permit Reference	137/020625
Grid Reference	SJ 64642 13475
Registered Office	EG on the Move Ltd Waterside Head Office Haslingdon Road Blackburn BB1 2FA
Registered Number	14960308

EG on the Move Ltd is hereby permitted by Telford & Wrekin Council to carry out the activity of the unloading of petrol into stationary storage tanks at a service station as defined under Schedule 1, , Part 2, Section 1.2, Part B (c), of The Environmental Permitting (England and Wales) Regulations 2016 ("The Regulations") and other activities as listed and described below within the installation boundary marked in orange on the attached plan in Appendix 1 and in accordance with the conditions within this permit.

Signed:

Name: Clair Travis

Date: 2 June 2025

Environmental Health Officer

Authorised by the Borough of Telford and Wrekin to sign in that behalf

Status log	Relevant Dates
Date permit first issued	14/042005
Date of previous variations	24/05/2005
	28/07/2006
	24/08/2011
	29/06/2016
Transfer of permit from Petrogas Ltd to EG on the Move Ltd	02/06/2025
Change of permit reference number from 07/00003/PFS to 137/020625	02/06/2025
Date of Latest Variation – Permit updated to latest statutory guidance for a stage I petrol station	02/06/2025

Introductory Note – This Introductory note does not form part of the permit.

Determination of application

Particular conditions have been inserted as representing the authority's judgement of what constitutes BAT, having regard to the statutory guidance issued by the Secretary of State and to all site-specific considerations.

Description of the Installation

This site has abatement equipment that minimises the emissions of petroleum into the atmosphere from the unloading of petrol from mobile tankers into stationary tanks (known as stage I controls).

This service station has 4 petroleum storage tanks, and 16 petroleum dispensing nozzles.

Stage I controls are:

Vapour recovery system which includes; delivery and return lines, manifold, pipework, vapour and tank connection points, poppet value, vent stacks and pressure release valve (PRV) is fitted to the vent on the manifold.

End of Introductory Note

Permit Conditions

General

1. The best available techniques shall be used to prevent, or where that is not practicable, reduce the emissions from the installation in relation to any aspect of the activity which is not specifically regulated by any condition of this permit.
2. An appropriate person (and deputy) shall be appointed as the primary point of contact with the regulator. The regulator shall be informed in writing of the appointed person (and deputy). In the event of a different person being appointed, the regulator shall be informed without delay.
3. A copy of this permit shall be kept at the installation. All relevant staff shall be made aware of its content and shall be told where it is kept.
4. If the operator proposes to make a change in the operation of the installation, they must, at least 14 days before making the change, notify the regulator on the appropriate form. The notification must contain a description of the proposed change in operation. A 'change in operation' means a change in the nature or functioning, or an extension, of the installation, which may have consequences for the environment.
5. All records required to demonstrate compliance with any conditions of this Permit shall be kept in an organised manner. The records shall be kept electronically or in paper form. Records:
 - a) Must be legible and any amendment entered into a record shall be made in such a way as to leave the original clear and legible.
 - b) Records shall be kept for a period of 4 years, unless otherwise stated.
 - c) Records shall be kept on-site for a minimum of 12 months. Records kept off-site, must be made available within 7 days of any request by the regulator.
6. All documentation required to be submitted to the regulator to demonstrate compliance with relevant conditions, shall be submitted in an electronic format. Submissions shall be sent to:
environmentalprotectionteam@telford.gov.uk

Petrol Delivery

7. Vapours displaced by the delivery of petrol into storage tanks shall be returned through a vapour-tight connection line to either the mobile container delivering the petrol or a container on the site.



8. Petrol delivery shall only be carried out using the Stage I petrol vapour recovery system and deliveries shall only be made when the system is fully operational.

Incident Reporting



9. In the event of any incident at the site which could have an impact beyond the site boundary, the operator shall notify Telford & Wrekin Council Environmental Protection Team without delay, by calling 01952 381 818 or emailing: environmentalprotectionteam@telford.gov.uk

Management

10. All relevant staff shall receive the necessary training and instruction to enable them to comply with the conditions of this permit.
11. Maintenance and testing of vapour recovery system shall be recorded.

Appendix 1. Location of Installation Plan



<p>Title</p> <p>Petrogas Group Limited Location plan & installation</p> <p>boundary indicated in orange</p>	<p>Telford & Wrekin Council Public Protection</p> <p>Telford & Wrekin Council Darby House, Town Centre Telford, Shropshire TF3 4LB</p>	<p>N</p> 	 <p>Telford & Wrekin COUNCIL</p> <p><small>Reproduced from (based upon) the Ordnance Survey mapping with the permission of the Controller of Her Majesty's Stationery Office. © Crown copyright. Unauthorised reproduction infringes Crown copyright and may lead to prosecution or civil proceedings. Borough of Telford & Wrekin Council. Licence Number: 100018994</small></p>
	<p>Scale : 1:1054</p>	<p>Drawn by: Not Set</p>	<p>Date: 4/11/15</p>

End of Permit Conditions

This section does not form part of the permit but contains guidance relevant to it.

Appeals

The operator can appeal against regulatory action by the regulator to the Secretary of State for Environment, Food & Rural Affairs. Appeals must be made in accordance with Regulation 31 and sent to the Secretary of State for Environment Food and Rural Affairs. The appeal for can be found at:

http://www.planning-inspectorate.gov.uk/pins/environment/environment/environmental_appeals/environmental_permitting_appeal_form.pdf

Guidance on the appeal procedure can be found at

http://www.planning-inspectorate.gov.uk/pins/environment/environment/environmental_appeals/environmental_permitting_guidance_notes.pdf

There are time limits for making an appeal as follows:

- a) in relation to an appeal against a revocation notice, before the notice takes effect;
- b) in relation to the withdrawal of a duly-made application under paragraph 4(2) of Schedule 5, not later than 15 working days from the date of the notice served under that paragraph;
- c) in relation to a variation notification, a suspension notice, an enforcement notice or a landfill closure notice, not later than 2 months from the date of the notification or notice;
- d) in any other case not later than 6 months from the date of the decision or deemed decision.

Please note:

An appeal will not suspend the effect of the conditions appealed against; the conditions must still be complied with.

In determining an appeal against one or more conditions, the Act allows the Secretary of State in addition to quash any of the other conditions not subject to the appeal and to direct the local authority either to vary any of these other conditions or to add new conditions.

Contact Numbers for the Regulator

The Regulator is the Public Protection Team of Telford & Wrekin Council. They can be contacted on 01925 381 818. You may also contact them by email at any time. environmentalprotectionteam@telford.gov.uk

Correspondence Address

All correspondence to Telford & Wrekin Council relating to this information shall be addressed to: Public Protection, Telford and Wrekin Council, Addenbrooke House, Telford, TF3 4NT